

STOCKTON SERVICES

**PO Box 1306, Hampton, NH 03843-1306
(603) 474-1954**

TEST PIT DATA FOR IN-KIND REPLACEMENT SYSTEM

LOCUS: 111 Woodland Road, North Hampton, NH

OWNER: Warren Myers

DATE: December 4, 2002

PRESENT: Anne W. Bialobrzewski (Designer #348)
Mike Oiler (MCO Excavators -Backhoe)
Mike Cuomo (Town Inspector)

TEST PIT DATA:

Location: Approx. 40' and across driveway from upslope corner of existing leach field.


0"-48" mixed fill from house and driveway construction

48"-54" 10YR 3/1 fine sandy loam (original topsoil)

54"-94" 10YR6/4 gravelly sandy loam, granular friable

ESHWT @60" (mottles), no observed water, no refusal to 94"

Elevation of ESHWT in test pit measured to be approx. 36" lower than bottom of stone in leach field. Agreed on site, OK to replace in kind.



Anne W. Bialobrzewski
Designer #348

Stockton Services
PO Box 1306
Hampton, NH 03843-1306

Date: February 28, 2001

Designer: Anne W. Bialobrzkeski (Permit #348)

Property Owner: Daniel McGrail

Location: 14 Brown Avenue, Stratham, NH 03885

Installer: Mike Oiler (MCO Excavators)

Witness (Town Inspector): Mike Cuomo

Test Pit Location: Approx 10' off southerly edge of leach field

Distance to existing well, surface water: 100'+


Test pit data: pit #1

0-6"	loam and root mat
6-28"	mixed color, predominantly 10YR 4/4 to 4/6 gravelly fine to medium sand, loose granular
28-31"	2.5Y 5/4 gravelly very fine sandy loam, firm, root limiting, restrictive, wet
31-64"	mixed color, predominantly 10YR 4/4 gravelly medium to coarse sand, loose granular

eshwt @ 28" (perched), seepage @ 28", no observed water below
restrictive layer, no refusal

depth to elevation of existing bed bottom = 4", using distribution box as
bench mark. Therefore 24" provided from bed bottom to perched eshwt
(town inspector concurs). OK to replace in kind.

Anne W. Bialobrzkeski



STOCKTON SERVICES

LAND USE CONSULTANTS

P.O. BOX 1306

HAMPTON, NEW HAMPSHIRE 03842

(603) 926-7795

DATE: MARCH 2, 1992

DESIGNER: A.W. BIALOBRZESKI

LOCATION: 8 FIFIELD LANE
STRATHAM, NH

OWNER: RICHARD MOULTON

INSTALLER: MIKE OILER

WITNESSED BY: J. HAYDEN (TOWN INSPECTOR)

TEST PIT LOCATION: 30'± BEHIND HOUSE

EST 5'± FROM EDGE OF FIELD

NO WELL OR SURFACE WATER WITHIN 100'

TEST PIT DATA:

0"-12" TOPSOIL, DARK BROWN LOAM (10YR 3/3)
GRANULAR FRIABLE

12"-30" YELLOWISH BROWN (10YR 5/6)
GRAVELLY SANDY LOAM
GRANULAR FRIABLE

30"-96" DARK YELLOWISH BROWN (10YR 4/4 TO 10YR 4/6)
GRAVELLY LOAMY MEDIUM SAND
LOOSE GRANULAR

ESH WT @ 57" (MOTTLES)

SEEPAGE @ 60"

NO REFUSAL

BASED ON TOP OF SEPTIC TANK, BED BOTTOM
IS 24" BELOW EXISTING GRADE AND IS
THEREFORE 33"± ABOVE ESH WT.

Anne W. Bialobrzeski
DESIGNER PERMIT #348

STOCKTON SERVICES

LAND USE CONSULTANTS

P.O. BOX 1306

HAMPTON, NEW HAMPSHIRE 03842

DATE: JAN 16, 1992
DESIGNER: ANNE W. BIALOBZESKI (603) 926-7799

LOCATION: 132 BUNKER HILL AVE
STRATHAM NH

OWNER: ~~CHARLES~~ CHARLES GOODWIN

INSTALLER: MIKE OILER

WITNESSED BY: JIM HAYDEN (TOWN INSPECTOR)

TEST PIT LOCATION: 80'± IN FRONT OF HOUSE
12'± FROM D-BOX
EST. 5'± FROM EDGE OF FIELD

TEST PIT DATA:

0-26" MIXED LOAM FILL $\frac{1}{2}$ ORIGINAL TOPSOIL
(TO BE REMOVED)

26"-36" 10YR 4/6 GRAVELLY COARSE SAND
LOOSE GRANULAR

36"-55" 10YR 5/6 GRAVELLY SANDY LOAM
GRANULAR FRIABLE
SOMEWHAT FIRM IN PLACE

55"-8' 2.5Y 5/3 FINE SANDY LOAM
GRANULAR FRIABLE, MOTTLED

ESHW@ 55", NO OBS H₂O, NO REFUSAL
NO SURFACE WATER WITHIN 100'

BASED ON TOP OF D-BOX, BED BOTTOM IS
24" BELOW SLIGHTLY HIGHER EXISTING
ADJACENT GRADE AND IS THEREFORE
31"± ABOVE ESHWT.

Anne W Bialobzeski

STOCKTON SERVICES
LAND USE CONSULTANTS
P.O. BOX 1306
HAMPTON, NEW HAMPSHIRE 03842
(603) 926-7795

DATE: 10/25/91

EVALUATOR: ANNE W. BIALOBRZESKI (PERMIT #348)

LOCATION: 8 MEADOW FOX LANE
NORTH HAMPTON, NH

OWNER: ROY BOURQUE

TEST PIT LOCATION: ADJACENT TO EXISTING DRY WELL
(REAR LOT AREA APPROX LEVEL)

TEST PIT DATA:

0-10" DARK YELLOWISH BROWN (10YR 3/4)
FINE SANDY LOAM, GRANULAR FRIABLE

10-19" YELLOWISH BROWN GRAVELLY
LOAMY COARSE SAND (10YR 5/6)
GRANULAR FRIABLE

19"-28" GRAVELLY COARSE SAND
MIXED COLOR (PREDOMINANTLY 10YR 4/4 TO
10YR 3/6), LOOSE GRANULAR

28"-38" YELLOWISH BROWN SLIGHTLY LOAMY
FINE TO MEDIUM SAND (10YR 5/6)
GRANULAR FRIABLE TO LOOSE

38"-120" GRAVELLY COARSE SAND
MIXED COLOR (PREDOM. 10YR 4/4 TO
10YR 3/6), LOOSE GRANULAR

NO OBS H₂O
NO EVIDENCE OF SHWT
NO REFUSAL
NO SURFACE WATER WITHIN
100' OF TEST PIT

Anne W. Bialobrzewski

TOP OF DRY WELL
28" BELOW GRADE
DRY WELL 4' DEEP
ASSUME 1' STONE UNDER
(BB 7.3' DOWN
PIT BOTTOM 10' DOWN)

STOCKTON SERVICES
LAND USE CONSULTANTS
P.O. BOX 1306
HAMPTON, NEW HAMPSHIRE 03842
(603) 926-7795

DATE: JUNE 25, 1993
DESIGNER: ANNE W. BIALOBRZESKI
LOCATION: 121 POST ROAD
NORTH HAMPTON
OWNER: GREG TABER

TEST PIT LOCATION: 4' OFF EXISTING DRY WELL
BEHIND HOUSE


NO WELL OR SURFACE WATER WITHIN 100'

TEST PIT DATA

0-12" DARK BROWN (10YR 3/3) ~~FINE~~ LOAM, GRANULAR FRIABLE
12"-28" DARK YELLOWISH BROWN (10YR 4/6) LOAMY
FINE TO MEDIUM SAND, GRANULAR FRIABLE
28"-40" DARK YELLOWISH BROWN (10YR 4/4 to 4/6)
GRANULAR, LOOSE GRAVELLY MEDIUM SAND
40"-96" DARK YELLOWISH BROWN (10YR 4/4)
GRAVELLY COARSE SAND, LOOSE

NO EVIDENCE OF SHW, NO OBSERVED WATER, NO REFUSAL

BOTTOM OF DRY WELL @ 48" DEPTH = 48" ABOVE
BOTTOM OF PIT (NO SHW TO 96")



Anne W. Bialobrzewski
Designer Permit #348